IAPMO OCEANIA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia /info@iapmooceania.org

www.jas-anz.org/register

CERTIFICATE OF CONFORMITY

IAPMO Oceania hereby grants to:

Green Drain Inc

A.B.N.:

20619 Torrence Chapel Rd. Suite 116-223 Cornelius, NC. 28031 866-444-0212 United States

Email: sales@greendrains.com.au

the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme;– Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceania's WaterMark Governance Rules.

Evaluated to:

WMTS-522:2021

Fixture and floor wastes- Supplementary protection devices

Manufacturer:

Refer to Licence Holder

Licence No.:	WM-022837	**First Certified:**	30 Jul 2018
Certification Date:	30 Jul 2026	**Expiry Date:**	29 Jul 2031

David Viola

Chief Executive Officer of the IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO Oceania, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO Oceania. This certificate can only be reproduced in its entirety. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."

WATERMARK CERTIFICATE OF CONFORMITY
SCHEDULE OF CERTIFIED PRODUCT

Certificate Holder

Green Drain Inc

A.B.N.:

20619 Torrence Chapel Rd. Suite 116-223 Cornelius, NC. 28031 866-444-0212 United States

Manufacturer

Refer to Licence Holder

Standard

WMTS-522:2021

Fixture and floor wastes- Supplementary protection devices

Licence No. WM-022837 **Certification Date:** 30 Jul 2026 **Expiry Date:** 29 Jul 2031 **First Certified:** 30 Jul 2018

Brand Name	Model Name	Model ID	Product Type	Product Description	Application	Nominal Size	Nominal Flow Rate	Material
Green Drain	N/A	GD125	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN32	Level C - 7.27 L/min Level U - 29.22 L/min	ABS + silicone
Green Drain	N/A	GD15	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN40	Level C - 24.21 L/min Level U - 51.55 L/min	ABS + silicone
Green Drain	N/A	GD2	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN50	Level C - 35.25 L/min Level U - 82.50 L/min	ABS + silicone
Green Drain	N/A	GD25	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN65	Level C - 33.80 L/min Level U - 72.50 L/min	ABS + silicone
Green Drain	N/A	GD3	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN80	Level C - 40.65 L/min Level U - 105.70 L/min	ABS + silicone
Green Drain	N/A	GD3/35	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN80	Level C - 40.65 L/min Level U - 105.70 L/min	ABS + silicone

Brand Name	Model Name	Model ID	Product Type	Product Description	Application	Nominal Size	Nominal Flow Rate	Material
Green Drain	N/A	GD35	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN90	Level C - 121.60 L/min Level U - 323.17 L/min	ABS + silicone
Green Drain	N/A	GD35/4	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN90	Level C - 121.60 L/min Level U - 323.17 L/min	ABS + silicone
Green Drain	N/A	GD4	Pipes and fittings	Floor drain barrier trap protection device to restrict sewer gases, insects, odours and evaporation from a trap seal.	Floor waste	DN100	Level C - 218.25 L/min Level U - >340.00 L/min	ABS + silicone

END RECORD **END RECORD**

David Viola
Chief Executive Officer of the IAPMO Group